

PSC No. 5 - WATER**COMPANY: NEW YORK AMERICAN WATER COMPANY, INC.****INITIAL EFFECTIVE DATE: MAY 29, 2016****LEAF NO.: 39****REVISION: 0****SUPERSEDING REVISION:****VII. INSTALLATION OF SERVICES (CONTINUED)**

- 4.2. The Company shall not be obligated to commence any construction until applicants either have obtained for it satisfactory easements or rights-of-way or have agreed to pay such costs as may be incurred if at their request the Company obtains such easements or rights-of-way, whenever these are required, from parties who are not applicants for service.

C. Ownership

1. Title to a service pipe and service connection installed within the territorial limits of a public street as hereinbefore defined shall be vested in the Company. Such service pipe and connections shall at all times remain the sole property of the Company and shall not be trespassed upon nor interfered with in any respect. The curb stop may not be used by the customer for turning on or shutting off the water supply but is for the exclusive use of the Company.
2. Service pipe and connections installed at applicant's expense on a private street shall at all times remain the sole property of the applicant, in whom title thereto shall vest.

D. Installation, Maintenance, Replacement and Inspection of Service Pipes

1. Service on Applicant's Property
 - 1.1. At his own expense, the applicant shall install and maintain the service pipe from the territorial limit of the street to the premises, and two valves, the first to be located just inside the building wall, and the second valve adjacent to and on the house side of the meter, permitting control of the water supply by the customer. On services requiring meters of one inch (1") size and under, the two valves shall be incorporated in a meter yoke. The meter yoke and valves shall be of a make and type approved by the Company. For this installation and maintenance thereof the customer shall employ a competent plumber and all work shall be performed in a manner satisfactory to the Company. The minimum size, materials, depth of cover and method of construction shall be the same as hereinafter specified for a service pipe installed by the Company. If any defects in workmanship or materials are found or if the customer's service pipe has not been installed in accordance with such specifications or with the Company's requirements, water service either will not be turned on or will be discontinued if such defects are not remedied.
2. Service pipes must be located in compliance with all sanitary regulations and, in no case, be less than ten feet (10') from any cesspool or sewerage lines unless the design is otherwise approved by the Company.
3. Inspection of Service Pipes - That portion of the service pipe without the territorial limits of any street, avenue, road or way, is to be approved by the Company before the trench is backfilled.
4. The service pipe outside the limits of any street, avenue, road or way that is for any highway purpose under the jurisdiction of the legislative body of any city, town, village, county or the State of New York, or other public place open to the general public for highway purposes, shall be installed by a

Issued by: Brian K. Bruce, President, 60 Brooklyn Avenue, Merrick, New York 11566