

PSC No: 19 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: April 29, 2016
Issued in compliance with Order in Case 15-E-0557 dated March 18, 2016

Leaf No. 160.39.5
Revision: 4
Superseding Revision: 3

GENERAL INFORMATION

17. Electric Hybrid Generating System Option

Applicable to any customer who owns or operates two types of electric generating equipment as defined in General Information Section 13, 14, 15, or 16 of this Schedule at the same location ("Hybrid Facility"). The Hybrid Facility Option is intended to allow hybrid facilities the benefit of net metering for qualified generation.

Customers electing service under this Section must operate in compliance with standards and requirements set forth in the Distributed Generation Interconnection Requirements found in P.S.C. No. 19 - Electricity, Section 10 and Addendum-SIR to P.S.C. No. 19. In addition, customers must execute the New York State Standardized Contract for Interconnection of New Distributed Generation Units with Capacity of 5 MW or Less Connected in Parallel with Utility Distribution Systems ("SIR Contract"), as contained within Addendum-SIR of P.S.C. No. 19 - Electricity.

Metering

The Company shall install metering appropriate for the customer's service classification that enables the Company to measure the electricity delivered to the customer and measure the qualified electricity supplied by the customer to the Company. Billing, netting or compensation for generation shall be consistent for the qualified generation as defined in General Sections 13, 14, 15, or 16. Where the Company determines additional meters should be installed, no additional meter costs shall be billed to the customer. When a second meter is requested by the customer that is not required by the Company, the customer shall be responsible for additional costs.