

PSC NO: 1 ELECTRICITY
COMPANY: VILLAGE OF WESTFIELD
INITIAL EFFECTIVE DATE: 6/22/16

LEAF: 27
REVISION: 0
SUPERSEDING REVISION:

SERVICE CLASSIFICATION NO.7 (cont.)

Single-phase inverters and inverter systems shall be verified upon initial parallel operation and once every four years as follows: the generator-owner shall interrupt the utility source and verify that the equipment automatically disconnects and does not reconnect for at least five minutes after the utility source is reconnected. The owner shall maintain a log of these operations for inspection by the connecting utility.

Any system that depends upon a battery for trip power shall be checked and logged at least annually for proper voltage. Once every four (4) years the battery must be either replaced or a discharge test per the Village of Westfield.

INTERCONNECTION INVENTORY

To ensure applications are addressed in a timely manner and monitor the overall interconnection activities, utilities shall submit an SIR inventory of projects to the Public Service Commission by January 31 and July 31 of each year. At a minimum the following information shall be provided in the inventory:

1. Company
2. Applicant Name
3. System Type
4. System Capacity
5. Protective Equipment
6. Application Review Start and End date
7. Preliminary Review Start and End date
8. CESIR Start and End date
9. Verification Testing date
10. Final Letter of Acceptance date

Issued by: Andrew Thompson Director of Public Works, 23 Elm Street, Westfield, NY 14787