

PSC No. 1 – Water
SUEZ WATER WESTCHESTER INC.
Initial Effective Date: December 16, 2016

Leaf No. 18
Revision: 0
Superseding Revision:

GENERAL INFORMATION

- (f) The curb box shall be set on a level with the finished grade of the ground or sidewalk and as near to the property line as practical.
- (g) Maintenance, including thawing of the street service connection, will be performed by the Company at its expense and risk.

10. ADVANCE STREET SERVICE CONNECTIONS IN PUBLIC AND PRIVATE STREETS:

- (a) Whenever an owner or occupant wishes the Company to install in a public or private street a street service connection through which service is not immediately desired, he shall make application for such advance connection on a form provided by the Company for such purpose.

SUPERSEDED: See Section 28, 11.

- (b) The Customer making such application shall pay in advance to the Company the estimated cost of the complete installation of such street connection, and when the installation is completed if the actual cost is less than the estimated, the Company shall refund to the Customer the difference between the actual cost and the amount deposited, or if the actual cost is greater than the amount deposited the Customer shall pay to the Company such difference.

- (c) Whenever regular water service is begun through such connection the Company shall refund the entire cost of such street service connection less depreciation at the rate of **five percent (5%)** per annum for the period such street service connection has been in the ground.

11. CUSTOMER'S SERVICE PIPES:

- (a) The Customer's service pipe between the property line and the structures on the premises to be supplied shall be furnished and installed by the Customer at his expense and risk. The pipe shall be of a size not smaller than the street service pipe and the minimum size shall be **three-quarter (3/4) inch**. The pipe shall be of ample strength to withstand the water pressures at the point where located and may be of red brass, copper, or such other kind of pipe as will conform to the reasonable requirements of the Company in furnishing adequate and safe service.
- (b) All Customer's service pipes hereafter shall be laid to provide a cover equal to that of the street service connection but in no case shall the cover be less than four feet. The service pipe shall be placed on firm and continuous earth so as to give unyielding and permanent support, and shall be installed in a trench at least two feet in a horizontal direction from any other trench wherein are laid gas pipe, sewer pipe or other facilities, public or private, unless otherwise specifically authorized and approved by the Company.

Issued by: David Stanton, President, 2525 Palmer Ave., New Rochelle, NY 10801