

PSC NO: 214 ELECTRICITY
COMPANY: NIAGARA MOHAWK POWER CORPORATION
INITIAL EFFECTIVE DATE: APRIL 1, 2013
STAMPS: Issued in Compliance with Order of PSC in Case 12-E-0201 issued March 15, 2013

LEAF: 11
REVISION: 10
SUPERSEDING REVISION: 8

GENERAL INFORMATION

V. TERMS AND CONDITIONS APPLICABLE TO SPECIFIC SERVICE CLASSIFICATIONS

B. Special Provisions (Continued)

- | | | |
|----|---------------------------|------|
| 5. | Customer Responsibilities | SC-4 |
| 6. | Customer Responsibilities | SC-3 |
| 7. | Customer Responsibilities | SC-6 |
| 8. | Customer Responsibilities | SC-2 |

Whereas the customer is the designated owner and responsible entity for the operation and maintenance of the infrastructure system receiving all or a portion of the service as stated herein, the customer is further responsible for the following requirements:

- a. The procurement, installation, operation, maintenance, repair, replacement and removal of all customer owned infrastructure, systems and equipment.
- b. The infrastructure system or equipment shall be constructed/installed/attached in accordance with all requirements and specifications of the applicable industry codes and standards, Company construction standards and specifications, and any requirements, specifications or standards of other joint owners/users and attachment licensees including, but not limited to, the installation of appropriate Company approved electric disconnect devices having electric distribution protection capability and associated grounding requirements.
- c. The infrastructure system wiring is to be approved by an inspection agency certified in the system wiring application being inspected and having appropriate authority in the applicable jurisdiction. The entire infrastructure system will be constructed/installed prior to the submission for connection to Company's supply circuitry.
- d. All supply connections/disconnections to the Company's distribution system are to be made by Company personnel or assigned designee.
- e. Customer shall furnish a scaled map/drawing and corresponding inventory list of its equipment for Company use prior to initial installation and as requested by the Company but not to exceed an annual cycle. The map/drawing and equipment inventory list shall indicate the location, ownership, type of device and/or light source, total operational wattage rating and the location and type of any underground system components in triplicate with its application for service. Location information will include the customer designated unique structure identification reference. Type of device will include the physical description, industry naming convention, nominal wattage rating and all component energy consumption values at maximum operating conditions in wattages. The required equipment and location identification system is to be acceptable to Company.