

P.S.C. No. 1 – Water
United Water New York Inc.
Initial Effective Date: **July 4, 2014**

Leaf No. 22.1
Revision: 1
Superseding Revision:

GENERAL INFORMATION

subject to the approval of the Company. The cost of installing and maintaining the meter housing is the responsibility of the Customer. When there is evidence of tampering or theft of service associated with a Customer's indoor meter, the Company reserves the right to require that Customer to relocate their indoor meter to an outdoor meter housing at the Customer's cost and in accordance with the provisions of this Tariff.

The Company, in its sole discretion, may permit meters to be installed indoors. Any meters installed indoors shall be located in a clean, dry, safe place not subject to great variations in temperature, at or near the front wall as close as possible to the point of entrance of the connecting pipe. Meters shall be on a support which is free from appreciable vibration and shall be supported firmly, not less than 12 inches nor more than 36 inches above the level of the floor. The location shall be such as to be easily accessible, with no inconvenience to the Customer or to the Company

C. If the meter housing is to be installed upon property which is not owned or controlled by the customer, the Company will require that the Customer obtain an easement.

D. The location of the meter and the arrangement of the fittings to be supplied by the Company and service pipe shall be subject to the inspection and approval by the Company. A gate valve is to be installed on the inlet and outlet side of the meter unless another type of valve is specified by the Company

E. For condominium units which are separately metered as provided in Tariff 3.4E, it is necessary to house the meters of several customers in a common area whether inside or outside of a building. The meter location shall be approved by the Company prior to the start of any construction. The company will require that provision for such a meter housing arrangement be contained in the declaration of the condominium association or deed conveying the unit to the customer on whose property the meters will be located.

Issued in compliance with the Commission Order **13-W-0295** dated June 26, 2014.

Issued by: M.J. Pointing, V.P. & Gen. Mgr., 360 West Nyack Road, West Nyack, NY 10994