

PSC No. 2 – Water  
UNITED WATER WESTCHESTER INC.  
Initial Effective Date: December 5, 2014

Leaf No. 17  
Revision: 0  
Superseding Revision:

### **GENERAL INFORMATION**

(d) Interest

Every deposit earns interest at a rate set annually by the Commission based on the current economic conditions and current charges paid for money borrowed by the Company, taking into account the expenses incurred by the Company in obtaining, handling, returning or crediting the sum deposited.

The interest must be paid to the Customer when the deposit is returned, in accordance with Deposit Return Section. If the deposit has been held for 12 consecutive months or more, the interest must be credited to the Customer no later than the first bill rendered after the next succeeding first day of October and at the end of each succeeding 12-month period.

(e) Deposit Return

The Company must return a deposit or portion of a deposit plus the applicable interest as soon as reasonably possible, but no more than 30 calendar days after the date of the first bill for service rendered after a 12 month period during which time the Customer was not delinquent.

## **9. STREET SERVICE CONNECTIONS IN PUBLIC AND PRIVATE STREETS:**

- (a) All applications for new street service connections or the replacement of existing street service connections in public **or** private streets shall be made on application forms provided by the Company.
- (b) The size of the street service connection shall be determined by the Company on the basis of information given on the application of the Customer. The minimum size for any street service hereafter installed shall however be three-quarter (3/4) inch with not less than a three-quarter (3/4) inch tap in the main.
- (c) Where immediate service is required, the street service connection from the main to the property line, including the curb cock and curb box, shall be furnished and installed at the expense of the Company. The Company will not be required to replace any existing street service connection with larger pipe unless the Customer has previously laid a pipe of a size adequate to care for the service demanded from the property line to the premises.
- (d) All street service connections shall be laid to provide a minimum cover of four (4) feet, but if the main to which the connection is made has a cover of more than four (4) feet then the street service connection shall be laid to have a cover equal to the cover of the main, provided that such cover need not exceed five (5) feet.
- (e) Taps in all mains having a cover of less than five (5) feet shall be made on the side of the main.