



Consolidated Edison Company  
of New York, Inc.  
4 Irving Place  
New York NY 10003  
www.conEd.com

December 16, 2016

Honorable Kathleen H. Burgess  
Secretary  
New York State Public Service Commission  
Three Empire State Plaza, 19<sup>th</sup> Floor  
Albany, New York 12223-1350

**RE: Case 16-E-0543, Rider T – Commercial Demand Response Programs**

Dear Secretary Burgess:

Consolidated Edison Company of New York, Inc. (“Con Edison” or the “Company”) is filing with the Public Service Commission (the “Commission”) an amendment to its Schedule for Electricity Service, P.S.C. No. 10 – Electricity (the “Tariff”), applicable to its customers in the City of New York and the County of Westchester.

The revised Tariff Leaf identified below has an effective date of December 22, 2016:

<u>Leaf No.</u>	<u>Revision No.</u>	<u>Superseding No.</u>
270	4	3

**Reason for Filing**

The Commission’s Order Approving Tariff Amendments With Modification (the “Order”), issued December 15, 2016, approved the Company’s filing made September 22, 2016, to revise Rider T, with one modification. On November 18, 2016, the Company submitted a letter to the Commission (“supplemental filing”) providing additional information and requesting one change to the Company’s September tariff filing. The Company proposed to issue an Advisory if the day-ahead forecasted load level is at least 92 percent (instead of 90 percent, as originally proposed) of the forecasted summer system-wide peak, to provide for consistency with the 92-percent threshold for a Planned Event. Because the supplemental filing did not contain a Tariff leaf to implement the requested modification, the Order directed the Company to file a Tariff amendment to reflect this change.

### **Tariff Change**

The Company filed a revised Tariff Leaf 270 to modify the definition of “Advisory” in its September 22, 2016 filing. The attached revised Leaf 270 modifies the September 22 filing to indicate that notice will be issued when the Company’s day-ahead forecasted load level is at least 92 percent of the forecasted summer system-wide peak.

### **Conclusion and Notice**

Pursuant to Ordering Clause 2, the Company is filing this Tariff Leaf on not less than one day’s notice to become effective on December 22, 2016. Pursuant to Ordering Clause 3, the requirement for newspaper publication of this change has been waived.

Sincerely,

/s/ William A. Atzl, Jr.  
Director  
Rate Engineering Department